

School Name: Taconic Hills Central School District

Lab ELAP ID#

Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/ Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-KF-1	10/8/2020	HS kitchen hand sink near walk-in	Kitchen sink	Initial	6.6	1/5/21	
Adirondack	TH-1-KF-2	10/8/2020	HS 2-bay sink near walk-in	Kitchen sink	Initial	5.8	1/5/2021	
Adirondack	TH-1-KF-3	10/8/2020	HS kitchen near entrance S1926	Kitchen sink	Initial	3.9	1/5/2021	
Adirondack	TH-1-KF-4	10/8/2020	HS kitchen sink near 1-bay near electrical panel	Kitchen sink	Initial	8.5	1/5/2021	
Adirondack	TH-1-KF-5	10/8/2020	HS 2-bay sink near dish line	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-6	10/8/2020	HS hand sink near ice machine	Kitchen sink	Initial	5.8	1/5/2021	
Adirondack	TH-1-IM-7	10/8/2020	HS ice machine - kitchen	Ice Machine	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-8	10/8/2020	HS hand sink in dishwashing bay	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-9	10/8/2020	HS 3-bay sink in dishwashing bay left	Kitchen sink	Initial	6.3	1/5/2021	
Adirondack	TH-1-KF-10	10/8/2020	HS 3-bay sink in dishwashing bay right	Kitchen sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-KF-11	10/8/2020	HS dish wash bay sprayer faucet	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-IM-12	10/8/2020	Ice machine E189	Ice Machine	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-13	10/8/2020	Elementary kitchen E183 hand sink electric panel HKB	Kitchen sink	Initial	7.8	1/5/2021	
Adirondack	TH-1-KF-14	10/8/2020	Elementary kitchen E183 1-bay sink near electric panel	Kitchen sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-KF-16	10/8/2020	Elementary E183 wash bay sprayer sink	Kitchen sink	Initial	8.7	1/5/2021	
Adirondack	TH-1-KF-17	10/8/2020	Elementary E183 wash bay 3-bay sink (left)	Kitchen sink	Initial	1.3	1/5/2021	
Adirondack	TH-1-KF-18	10/8/2020	Elementary E183 wash bay 3-bay sink (right)	Kitchen sink	Initial	2.2	1/5/2021	
Adirondack	TH-1-KF-19	10/8/2020	Elementary E183 wash bay hand sink	Kitchen sink	Initial	7.0	1/5/2021	
Adirondack	TH-1-CF-20	10/8/2020	E109 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-21	10/8/2020	E109 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-22	10/8/2020	E109 bathroom sink	Bathroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-1-BF-23	10/8/2020	E112 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-24	10/8/2020	E112 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-25	10/8/2020	E112 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-26	10/8/2020	E110 conference room sink	Kitchen sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-NS-27	10/8/2020	E103 Health center nurse sink	Nurse sink	Initial	ND	1/5/2021	
Adirondack	TH-1-NS-28	10/8/2020	E103C exam room nurse sink	Nurse sink	Initial	2.6	1/5/2021	
Adirondack	TH-1-BF-29	10/8/2020	E103 Health center bathroom sink	Bathroom sink	Initial	1.7	1/5/2021	
Adirondack	TH-1-NS-30	10/8/2020	E103B exam room nurse sink	Nurse sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-BF-31	10/8/2020	Men's room - E104G	Bathroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-BF-32	10/8/2020	Women's room - E104F	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-33	10/8/2020	Water cooler near E104	Water Cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-34	10/8/2020	E102 classroom sink	Classroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-1-DW-35	10/8/2020	E102 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-36	10/8/2020	Water cooler near E122	Water Cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-37	10/8/2020	E121 bathroom	Bathroom sink	Initial	1.6	1/5/2021	
Adirondack	TH-1-CF-38	10/8/2020	E121 classroom sink	Classroom sink	Initial	4.5	1/5/2021	
Adirondack	TH-1-DW-39	10/8/2020	E121 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-40	10/8/2020	E122 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-41	10/8/2020	E122 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-42	10/8/2020	E122 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/ Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-Bf-43	10/8/2020	E123 bathroom sink	Bathroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-CF-44	10/8/2020	E123 classroom sink	Classroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-DW-45	10/8/2020	E123 bubbler	Water fountain	Initial	2.3	1/5/2021	
Adirondack	TH-1-CF-46	10/8/2020	E127 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-47	10/8/2020	E127 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-48	10/8/2020	E127 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-49	10/8/2020	E128 bathroom sink	Bathroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-CF-50	10/8/2020	E128 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-51	10/8/2020	E128 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-52	10/8/2020	E129 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-DW-53	10/8/2020	E129 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-54	10/8/2020	E129 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-55	10/8/2020	E130 bathroom sink	Bathroom sink	Initial	3.4	1/5/2021	
Adirondack	TH-1-CF-56	10/8/2020	E130 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-57	10/8/2020	E130 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-58	10/8/2020	E209 bathroom sink	Bathroom sink	Initial	1.2	1/5/2021	
Adirondack	TH-2-CF-59	10/8/2020	E209 classroom sink	Classroom sink	Initial	1.0	1/5/2021	
Adirondack	TH-2-DW-60	10/8/2020	E209 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-61	10/8/2020	E207 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-62	10/8/2020	E207 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-63	10/8/2020	E207 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-64	10/8/2020	E210 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-65	10/8/2020	E210 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-66	10/8/2020	E210 bathroom sink	Bathroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-CF-67	10/8/2020	E212 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-68	10/8/2020	E212 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-69	10/8/2020	E212 bathroom sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-WC-70	10/8/2020	Water cooler across from E208	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-71	10/8/2020	E202C men's bathroom	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-72	10/8/2020	E202B women's bathroom	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-73	10/8/2020	A104 girl's locker room sink (left)	Bathroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-WC-75	10/8/2020	Water cooler near A104	Water Cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-76	10/8/2020	Bottle filler near A104	Bottle Fill	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-77	10/8/2020	A103 boy's locker room sink (left)	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-78	10/8/2020	A103 boy's locker room sink (right)	Bathroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-1-KF-79	10/8/2020	A102 sink	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-80	10/8/2020	Football men's room	Bathroom sink	Initial	1.7	1/5/2021	
Adirondack	TH-1-BF-81	10/8/2020	Football women's room	Bathroom sink	Initial	1.7	1/5/2021	
Adirondack	TH-1-BF-82	10/8/2020	Baseball women's	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-83	10/8/2020	Baseball men's	Bathroom sink	Initial	10.6	1/5/2021	
Adirondack	TH-2-CF-84	10/15/2020	E201 classroom sink	Classroom sink	Initial	ND	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-2-DW-85	10/15/2020	E201 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-86	10/15/2020	E201 bathroom sink	Bathroom sink	Initial	3.8	1/5/2021	
Adirondack	TH-2-CF-87	10/15/2020	E203 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-88	10/15/2020	E203 bubbler	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-89	10/15/2020	E203 bathroom sink	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-2-BF-90	10/15/2020	E204 bathroom sink	Bathroom sink	Initial	2.6	1/5/2021	
Adirondack	TH-2-CF-91	10/15/2020	E204 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-92	10/15/2020	E204 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-93	10/15/2020	E220 bathroom sink	Bathroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-2-CF-94	10/15/2020	E220 classroom sink	Classroom sink	Initial	16.1	1/5/2021	Faucet replaced and flushed
Adirondack	TH-2-DW-95	10/15/2020	E220 bubbler	Water fountain	Initial	22.4	1/5/2021	Faucet replaced and flushed
Adirondack	TH-2-CF-96	10/15/2020	E269 classroom sink	Classroom sink	Initial	21.9	1/5/2021	Faucet replaced and flushed
Adirondack	TH-2-DW-97	10/15/2020	E269 bubbler	Water fountain	Initial	13.5	1/5/2021	
Adirondack	TH-2-CF-98	10/15/2020	E270 classroom sink	Classroom sink	Initial	30.4	1/5/2021	Faucet replaced and flushed
Adirondack	TH-2-DW-99	10/15/2020	E270 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-100	10/15/2020	E272 classroom sink	Classroom sink	Initial	1.0	1/5/2021	
Adirondack	TH-2-DW-101	10/15/2020	E272 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-102	10/15/2020	E271 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-DW-103	10/15/2020	E271 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-104	10/15/2020	E267 classroom sink	Classroom sink	Initial	1.6	1/5/2021	
Adirondack	TH-2-DW-105	10/15/2020	E267 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-106	10/15/2020	E268 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-DW-107	10/15/2020	E268 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-108	10/15/2020	E265A boy's room sink (left)	Bathroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-2-BF-109	10/15/2020	E265A boy's room sink (middle)	Bathroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-2-BF-110	10/15/2020	E265A boy's room sink (right)	Bathroom sink	Initial	1.5	1/5/2021	
Adirondack	TH-2-BF-111	10/15/2020	E266A girl's room sink (left)	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-2-BF-112	10/15/2020	E266A girl's room sink (middle)	Bathroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-2-BF-113	10/15/2020	E266A girl's room sink (right)	Bathroom sink	Initial	2.5	1/5/2021	
Adirondack	TH-2-CF-114	10/15/2020	E265 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-115	10/15/2020	E265 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-116	10/15/2020	E266 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-117	10/15/2020	E266 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-WC-118	10/15/2020	Water cooler near E266	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-119	10/15/2020	E264 classroom sink	Classroom sink	Initial	1.6	1/5/2021	
Adirondack	TH-2-DW-120	10/15/2020	E264 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-121	10/15/2020	E262 classroom sink	Classroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-2-DW-122	10/15/2020	E262 bubbler	Water fountain	Initial	2.1	1/5/2021	
Adirondack	TH-2-CF-123	10/15/2020	E263 classroom sink	Classroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-2-DW-124	10/15/2020	E263 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-125	10/15/2020	E261 classroom sink	Classroom sink	Initial	ND	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/ Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-2-DW-126	10/15/2020	E261 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-127	10/15/2020	E261C men's room sink	Bathroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-2-BF-128	10/15/2020	E261B women's room sink	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-KF-129	10/15/2020	E260 sink	Kitchen sink	Initial	1.5	1/5/2021	
Adirondack	TH-2-CF-130	10/15/2020	E251 left	Classroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-2-CF-131	10/15/2020	E251 right	Classroom sink	Initial	3.7	1/5/2021	
Adirondack	TH-2-CF-132	10/15/2020	E255 classroom sink	Classroom sink	Initial	1.5	1/5/2021	
Adirondack	TH-2-DW-133	10/15/2020	E255 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-134	10/15/2020	E252 bathroom	Bathroom sink	Initial	2.6	1/5/2021	
Adirondack	TH-2-CF-135	10/15/2020	E252 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-136	10/15/2020	E252 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-137	10/15/2020	E254 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-138	10/15/2020	E254 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-139	10/15/2020	E254 bathroom	Bathroom sink	Initial	2.1	1/5/2021	
Adirondack	TH-2-CF-140	10/15/2020	E256 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-BF-141	10/15/2020	E256 bathroom	Bathroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-2-CF-142	10/15/2020	E258 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-DW-143	10/15/2020	E258 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-KF-144	10/15/2020	S259 sink	Kitchen sink	Initial	1.3	1/5/2021	
Adirondack	TH-2-WC-145	10/15/2020	Water cooler near S259	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-146	10/15/2020	E171 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-147	10/15/2020	E171 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-148	10/15/2020	E169 classroom	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-149	10/15/2020	E169 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-150	10/15/2020	E172 classroom	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-151	10/15/2020	E172 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-152	10/15/2020	E170 classroom sink	Classroom sink	Initial	1.5	1/5/2021	
Adirondack	TH-1-DW-153	10/15/2020	E170 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-154	10/15/2020	E167 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-155	10/15/2020	E167 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-156	10/15/2020	E168 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-157	10/15/2020	E168 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-158	10/15/2020	E165A boy's room (left)	Bathroom sink	Initial	1.2	1/5/2021	
Adirondack	TH-1-BF-159	10/15/2020	E165A boy's room (middle)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-BF-160	10/15/2020	E165A boy's room (right)	Bathroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-BF-161	10/15/2020	E166A girl's room (left)	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-162	10/15/2020	E166A girl's room (middle)	Bathroom sink	Initial	1.2	1/5/2021	
Adirondack	TH-1-BF-163	10/15/2020	E166A girl's room (right)	Bathroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-CF-164	10/15/2020	E165 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-165	10/15/2020	E165 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-166	10/15/2020	E166 classroom sink	Classroom sink	Initial	ND	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID#

Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-DW-167	10/15/2020	E166 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-168	10/15/2020	Water cooler near E166	Water Cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-169	10/15/2020	E163 classroom sink	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-DW-170	10/15/2020	E163 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-171	10/15/2020	E164 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-DW-172	10/15/2020	E164 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-173	10/15/2020	E162 classroom sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-DW-174	10/15/2020	E162 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-175	10/15/2020	E161C men's room	Bathroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-1-BF-176	10/15/2020	E161B women's room	Bathroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-CF-177	10/15/2020	E161 classroom sink	Classroom sink	Initial	1.3	1/5/2021	
Adirondack	TH-1-DW-178	10/15/2020	E161 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-179	10/15/2020	E160 sink	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-180	10/15/2020	E141 Elementary Library Bathroom	Bathroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-KF-181	10/15/2020	E141 Library office	Kitchen sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-CF-182	10/15/2020	E140 Classroom sink	Classroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-DW-183	10/15/2020	E140 bubbler	Water fountain	Initial	1.4	1/5/2021	
Adirondack	TH-1-CF-184	10/15/2020	E144 classroom sink (left)	Classroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-CF-185	10/15/2020	E144 classroom sink (right)	Classroom sink	Initial	2.9	1/5/2021	
Adirondack	TH-1-CF-186	10/15/2020	E146 classroom sink (left)	Classroom sink	Initial	4.4	1/5/2021	
Adirondack	TH-1-CF-187	10/15/2020	E146 classroom sink (right)	Classroom sink	Initial	5.2	1/5/2021	
Adirondack	TH-1-CF-188	10/28/2020	E142 classroom sink	Classroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-1-DW-189	10/28/2020	E142 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-190	10/28/2020	E142C water cooler (left)	Water cooler	Initial	1.2	1/5/2021	
Adirondack	TH-1-WC-191	10/28/2020	E142C water cooler (right)	Water cooler	Initial	1.1	1/5/2021	
Adirondack	TH-1-BF-192	10/28/2020	E142C boys room (left)	Bathroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-BF-193	10/28/2020	E142C boys room (right)	Bathroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-BF-194	10/28/2020	E144C girls room (left)	Bathroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-BF-195	10/28/2020	E144C girls room (right)	Bathroom sink	Initial	2.1	1/5/2021	
Adirondack	TH-1-WC-196	10/28/2020	Bottle fill near E144C	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-197	10/28/2020	Water cooler near E144C	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-198	10/28/2020	Water cooler near Elementary Cafeteria	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-199	10/28/2020	E152 sink	Classroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-BF-200	10/28/2020	E152A boys room (left)	Bathroom sink	Initial	2.6	1/5/2021	
Adirondack	TH-1-BF-201	10/28/2020	E152A boys room (right)	Bathroom sink	Initial	2.5	1/5/2021	
Adirondack	Th-1-BF-202	10/28/2020	E154A girls room (left)	Bathroom sink	Initial	3.5	1/5/2021	
Adirondack	TH-1-BF-203	10/28/2020	E154A girls room (right)	Bathroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-BF-204	10/28/2020	E154 music sink	Bathroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-1-BF-205	10/28/2020	E156 classroom sink	Bathroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-BF-206	10/28/2020	S159 Mens room (left)	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-1-BF-207	10/28/2020	S159 mens room (right)	Bathroom sink	Initial	3.1	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID#

Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/ Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-WC-208	10/28/2020	Bottle fill near 5159	Water cooler	Initial	ND	1/5/2021	
Adirondack	Th-1-WC-209	10/28/2020	Water cooler near 5159	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-210	10/28/2020	S157 Ticket booth sink	Kitchen sink	Initial	5.0	1/5/2021	
Adirondack	TH-1-WC-211	10/28/2020	Water cooler near 5155	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-212	10/28/2020	S153 womens room (left)	Bathroom sink	Initial	3.8	1/5/2021	
Adirondack	TH-1-BF-213	10/28/2020	S153 womens room (right)	Bathroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-WC-214	10/28/2020	S158A watercooler	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-215	10/28/2020	S158C womens dressing room	Bathroom sink	Initial	8.0	1/5/2021	
Adirondack	TH-1-BF-216	10/28/2020	S158 B mens dressing room	Bathroom sink	Initial	5.1	1/5/2021	
Adirondack	TH-1-KF-217	10/28/2020	S152A sink	Kitchen sink	Initial	4.1	1/5/2021	
Adirondack	TH-1-DW-218	10/28/2020	S152A bubbler	Water fountain	Initial	2.3	1/5/2021	
Adirondack	TH-1-BF-219	10/28/2020	S195 mens locker room	Bathroom sink	Initial	6.2	1/5/2021	
Adirondack	TH-1-BF-220	10/28/2020	S194 boys locker room (left)	Bathroom sink	Initial	14.8	1/5/2021	
Adirondack	TH-1-BF-221	10/28/2020	S194 boys locker room (middle)	Bathroom sink	Initial	14	1/5/2021	
Adirondack	TH-1-BF-222	10/28/2020	S194 boys locker room (right)	Bathroom sink	Initial	8.1	1/5/2021	
Adirondack	TH-1-WC-223	10/28/2020	Water cooler near 5151 Hs/Ms gym	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-224	10/28/2020	S198 womens locker room	Bathroom sink	Initial	6.7	1/5/2021	
Adirondack	TH-1-BF-225	10/28/2020	Girls locker room (left)	Bathroom sink	Initial	28.5	1/5/2021	Bathroom sink with mixing valve labeled do not drink
Adirondack	TH-1-BF-226	10/28/2020	Girls locker room (middle)	Bathroom sink	Initial	4.5	1/5/2021	
Adirondack	TH-1-BF-227	10/28/2020	Girls locker room (right)	Bathroom sink	Initial	11.5	1/5/2021	
Adirondack	TH-1-BF-228	10/28/2020	E191A womens room	Bathroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-BF-229	10/28/2020	E191 girls locker room (left)	Bathroom sink	Initial	12.5	1/5/2021	
Adirondack	TH-1-BF-230	10/28/2020	E191 girls locker room (middle)	Bathroom sink	Initial	6.1	1/5/2021	
Adirondack	TH-1-BF-231	10/28/2020	E191 girls locker room (right)	Bathroom sink	Initial	5.4	1/5/2021	
Adirondack	TH-1-BF-232	10/28/2020	E187 boys locker room (left)	Bathroom sink	Initial	7.9	1/5/2021	
Adirondack	TH-1-BF-233	10/28/2020	E187 boys locker room (middle)	Bathroom sink	Initial	5.5	1/5/2021	
Adirondack	TH-1-BF-234	10/28/2020	E187 boys locker room (right)	Bathroom sink	Initial	8.2	1/5/2021	
Adirondack	TH-1-BF-235	10/28/2020	E187A mens room	Bathroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-WC-236	10/28/2020	Water cooler near elementary gym	Water cooler	Initial	4.3	1/5/2021	
Adirondack	TH-1-WC-237	10/28/2020	Water cooler near E151 elementary gym rear (right)	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-238	10/28/2020	Water cooler near E151 elementary gym front	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-239	10/28/2020	Water cooler near E151 elementary gym rear (left)	Water cooler	Initial	2.5	1/5/2021	
Adirondack	TH-1-WC-240	10/28/2020	Water cooler middle school gym rear	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-241	10/28/2020	Water cooler middle school gym front (right)	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-243	10/28/2020	Water cooler middle school front (left)	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-244	10/28/2020	Water cooler high school gym rear	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-245	10/28/2020	Water cooler high school gym front	Water cooler	Initial	1.0	1/5/2021	
Adirondack	TH-1-KF-246	10/28/2020	S191 copy center	Kitchen sink	Initial	1.0	1/5/2021	
Adirondack	TH-1-BF-247	10/28/2020	S143 B mens room	Bathroom sink	Initial	3.8	1/5/2021	
Adirondack	TH-1-BF-248	10/28/2020	S143 C womens room	Bathroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-1-BF-249	10/28/2020	S172 A girls room (left)	Bathroom sink	Initial	3.1	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-BF-250	10/28/2020	S172 A girls room (right)	Bathroom sink	Initial	3.7	1/5/2021	
Adirondack	TH-1-BF-251	10/28/2020	S172 B boys room (left)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-BF-252	10/28/2020	S172 B boys room (right)	Bathroom sink	Initial	4.0	1/5/2021	
Adirondack	TH-1-KF-253	10/28/2020	S174 A sink	Kitchen sink	Initial	1.6	1/5/2021	
Adirondack	TH-1-DW-254	10/28/2020	S174 A bubbler	Water fountain	Initial	1.2	1/5/2021	
Adirondack	TH-1-CF-255	10/28/2020	S173 A	Classroom sink	Initial	1.6	1/5/2021	
Adirondack	TH-1-CF-256	10/28/2020	S173 B	Classroom sink	Initial	1.5	1/5/2021	
Adirondack	TH-1-CF-257	10/28/2020	S173 C	Classroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-1-CF-258	10/28/2020	S173 D	Classroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-CF-259	10/28/2020	S173 E	Classroom sink	Initial	2.5	1/5/2021	
Adirondack	TH-1-CF-260	10/28/2020	S173 F	Classroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-CF-261	10/28/2020	S173 Prep	Classroom sink	Initial	4.6	1/5/2021	
Adirondack	TH-1-CF-262	10/28/2020	S175 A	Classroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-1-CF-263	10/28/2020	S175 B	Classroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-CF-264	10/28/2020	S175 C	Classroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-CF-265	10/28/2020	S175 D	Classroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-CF-266	10/28/2020	S175 E	Classroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-1-CF-267	10/28/2020	S175 F	Classroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-CF-268	10/28/2020	S179 A	Classroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-CF-269	10/28/2020	S179 B	Classroom sink	Initial	4.0	1/5/2021	
Adirondack	TH-1-CF-270	10/28/2020	S179 C	Classroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-1-CF-271	10/28/2020	S179 D	Classroom sink	Initial	2.9	1/5/2021	
Adirondack	TH-1-CF-272	10/28/2020	S179 E	Classroom sink	Initial	5.2	1/5/2021	
Adirondack	TH-1-CF-273	10/28/2020	S179 Prep	Classroom sink	Initial	2.9	1/5/2021	
Adirondack	TH-1-CF-274	10/28/2020	S176 A	Classroom sink	Initial	14.7	1/5/2021	
Adirondack	TH-1-CF-275	10/28/2020	S176 B	Classroom sink	Initial	1.2	1/5/2021	
Adirondack	TH-1-CF-276	10/28/2020	S176 D	Classroom sink	Initial	3.8	1/5/2021	
Adirondack	TH-1-CF-277	10/28/2020	S180 A	Classroom sink	Initial	6.3	1/5/2021	
Adirondack	TH-1-CF-278	10/28/2020	S180 B	Classroom sink	Initial	13.0	1/5/2021	
Adirondack	TH-1-CF-279	10/28/2020	S180 C	Classroom sink	Initial	19.9	1/5/2021	Faucet replaced and flushed
Adirondack	TH-1-CF-280	10/28/2020	S180 D	Classroom sink	Initial	9.1	1/5/2021	
Adirondack	TH-1-CF-281	10/28/2020	S181 A	Classroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-CF-282	10/28/2020	S181 B	Classroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-CF-283	10/28/2020	S181 C	Classroom sink	Initial	2.5	1/5/2021	
Adirondack	TH-1-CF-284	10/28/2020	S181 D	Classroom sink	Initial	2.1	1/5/2021	
Adirondack	TH-1-CF-286	10/28/2020	S183 A hood sink	Classroom sink	Initial	115	1/5/2021	Science sink labeled do not drink
Adirondack	TH-1-CF-287	10/28/2020	S183 B	Classroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-1-CF-288	10/28/2020	S183 C	Classroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-CF-289	10/28/2020	S183 D	Classroom sink	Initial	2	1/5/2021	
Adirondack	TH-1-CF-290	10/28/2020	S183 E	Classroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-CF-291	10/28/2020	S183 F	Classroom sink	Initial	1.9	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-CF-292	10/28/2020	S183 G (prep room hood)	Classroom sink	Initial	117	1/5/2021	Science sink labeled do not drink
Adirondack	TH-1-DW-293	10/28/2020	Water cooler near S183	Water fountain	Initial	1.4	1/5/2021	
Adirondack	TH-1-CF-294	10/28/2020	S187 A	Classroom sink	Initial	5.6	1/5/2021	
Adirondack	TH-1-CF-295	10/28/2020	S187 B	Classroom sink	Initial	6.3	1/5/2021	
Adirondack	TH-1-CF-296	10/28/2020	S187 C	Classroom sink	Initial	5	1/5/2021	
Adirondack	TH-1-CF-297	10/28/2020	S187 D	Classroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-1-BF-298	10/28/2020	S185 A mens room (left)	Bathroom sink	Initial	12.5	1/5/2021	
Adirondack	TH-1-BF-299	10/28/2020	S185 A mens room (right)	Bathroom sink	Initial	3.9	1/5/2021	
Adirondack	TH-1-CF-300	10/28/2020	S184 (left)	Classroom sink	Initial	9.9	1/5/2021	
Adirondack	TH-1-CF-301	10/28/2020	S184 (middle)	Classroom sink	Initial	15.9	1/5/2021	Technologies sink labeled do not drink
Adirondack	TH-1-CF-302	10/28/2020	S184 (right)	Classroom sink	Initial	5.7	1/5/2021	
Adirondack	TH-1-CF-303	10/28/2020	S186 (left)	Classroom sink	Initial	6.1	1/5/2021	
Adirondack	TH-1-CF-304	10/28/2020	S186 (right)	Classroom sink	Initial	8.1	1/5/2021	
Adirondack	TH-1-CF-305	11/17/2020	S181 E	Classroom sink	Initial	ND	1/5/2021	
Adirondack	TH-1-CF-306	11/17/2020	S181 F	Classroom sink	Initial	1.8	1/5/2021	
Adirondack	TH-1-CF-307	11/17/2020	S187 Prep room	Classroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-1-CF-308	11/17/2020	S176 C	Classroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-WC-310	11/17/2020	HS café watercoler (rear)	Water coler	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-311	11/17/2020	S183B Elementary hand sink kitchen	Kitchen sink	Initial	7.0	1/5/2021	
Adirondack	TH-1-BF-312	11/17/2020	A104 girls locker room sink (right)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-WC-314	11/17/2020	Water cooler fountain near S144 B	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-315	11/17/2020	S144 B boys room (left)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-BF-316	11/17/2020	S144 B boys room (right)	Bathroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-BF-318	11/17/2020	S142 C girls room (right)	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-1-WC-319	11/17/2020	Water cooler near 5142 C (left)	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-320	11/17/2020	Water cooler near 5142 C (right)	Water cooler	Initial	1.0	1/5/2021	
Adirondack	TH-1-CF-321	11/17/2020	HS Library office sink	Classroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-CF-322	11/17/2020	S140 (left)	Classroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-CF-323	11/17/2020	S140 (right)	Classroom sink	Initial	2.9	1/5/2021	
Adirondack	TH-1-CF-324	11/17/2020	S142 near door (A)	Classroom sink	Initial	3.2	1/5/2021	
Adirondack	TH-1-CF-325	11/17/2020	S142 opposite (B)	Classroom sink	Initial	2.5	1/5/2021	
Adirondack	TH-1-WC-326	11/17/2020	Water cooler near 5102	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-327	11/17/2020	S102 board room (left)	Kitchen sink	Initial	ND	1/5/2021	
Adirondack	TH-1-KF-328	11/17/2020	S102 board room (right)	Kitchen sink	Initial	1.2	1/5/2021	
Adirondack	TH-1-BF-329	11/17/2020	Business Admin bathroom	Bathroom sink	Initial	2.6	1/5/2021	
Adirondack	TH-1-BF-330	11/17/2020	Superintendent bathroom	Bathroom sink	Initial	2.9	1/5/2021	
Adirondack	Th-1-KF-331	11/17/2020	B&G kitchen	Kitchen sink	Initial	1.9	1/5/2021	
Adirondack	TH-1-BF-332	11/17/2020	S104 A mens room	Bathroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-1-BF-333	11/17/2020	S102 A womens room	Bathroom sink	Initial	1.7	1/5/2021	
Adirondack	TH-1-KF-334	11/17/2020	S101	Kitchen sink	Initial	2.0	1/5/2021	
Adirondack	TH-1-BF-335	11/17/2020	S112 J mens room (left)	Bathroom sink	Initial	2.9	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID# Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-1-BF-336	11/17/2020	S112 J mens room (right)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-WC-337	11/17/2020	Water cooler near S112 K	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-1-BF-338	11/17/2020	S112 L womens room (left)	Bathroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-1-BF-339	11/17/2020	S112 L womens room (right)	Bathroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-1-NS-340	11/17/2020	S113 B HS nurse exam A	Nurse Sink	Initial	4.9	1/5/2021	
Adirondack	TH-1-BF-341	11/17/2020	HS Nurse bathroom	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-1-NS-342	11/17/2020	HS nurse exam B 5113 C	Nurse Sink	Initial	4.1	1/5/2021	
Adirondack	TH-1-NS-343	11/17/2020	HS Nurse office sink 5113	Nurse Sink	Initial	3.5	1/5/2021	
Adirondack	TH-2-CF-344	11/17/2020	S219	Classroom sink	Initial	2.6	1/5/2021	
Adirondack	TH-2-DW-345	11/17/2020	S219 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-346	11/17/2020	S217 A	Classroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-2-CF-347	11/17/2020	S217 B	Classroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-2-CF-348	11/17/2020	S217 C	Classroom sink	Initial	4.2	1/5/2021	
Adirondack	TH-2-CF-349	11/17/2020	S217 D	Classroom sink	Initial	4.4	1/5/2021	
Adirondack	TH-2-CF-350	11/17/2020	S217 E	Classroom sink	Initial	3.2	1/5/2021	
Adirondack	TH-2-CF-351	11/17/2020	S218	Classroom sink	Initial	4.7	1/5/2021	
Adirondack	TH-2-DW-352	11/17/2020	S218 bubbler	Water fountain	Initial	4.7	1/5/2021	
Adirondack	TH-2-CF-353	11/17/2020	S216	Classroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-2-DW-354	11/17/2020	S216 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-355	11/17/2020	S216 A girls room (far left)	Bathroom sink	Initial	175	1/5/2021	Removed from service
Adirondack	TH-2-BF-356	11/17/2020	S216 A girls room (middle left)	Bathroom sink	Initial	27.9	1/5/2021	Removed from service
Adirondack	TH-2-BF-357	11/17/2020	S216 A girls room (middle right)	Bathroom sink	Initial	69.7	1/5/2021	Removed from service
Adirondack	TH-2-BF-358	11/17/2020	S216 A girls room (far right)	Bathroom sink	Initial	69.2	1/5/2021	Removed from service
Adirondack	TH-2-WC-359	11/17/2020	Water cooler near 5216 A	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-360	11/17/2020	S213	Classroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-2-DW-361	11/17/2020	S213 Bubbler	Water fountain	Initial	1.4	1/5/2021	
Adirondack	TH-2-CF-362	11/17/2020	S211	Classroom sink	Initial	4.7	1/5/2021	
Adirondack	TH-2-DW-363	11/17/2020	S211 bubbler	Water fountain	Initial	1.2	1/5/2021	
Adirondack	TH-2-CF-364	11/17/2020	S214	Classroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-2-DW-365	11/17/2020	S214 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-366	11/17/2020	S212	Classroom sink	Initial	2.1	1/5/2021	
Adirondack	TH-2-DW-367	11/17/2020	S212 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-368	11/17/2020	S212 C womens room	Bathroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-2-BF-369	11/17/2020	S212 B mens room	Bathroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-2-CF-370	11/17/2020	S201	Classroom sink	Initial	2.8	1/5/2021	
Adirondack	TH-2-DW-371	11/17/2020	S201 bubbler	Water fountain	Initial	1.1	1/5/2021	
Adirondack	TH-2-CF-372	11/17/2020	S203	Classroom sink	Initial	3.9	1/5/2021	
Adirondack	TH-2-DW-373	11/17/2020	S203 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-374	11/17/2020	S207 A	Classroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-2-CF-375	11/17/2020	S207 B	Classroom sink	Initial	2.0	1/5/2021	
Adirondack	TH-2-CF-377	11/17/2020	S207 D	Classroom sink	Initial	1.9	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID#

Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/ Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-2-CF-378	11/17/2020	S207 E	Classroom sink	Initial	3.3	1/5/2021	
Adirondack	TH-2-CF-379	11/17/2020	S209	Classroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-2-DW-380	11/17/2020	S209 bubbler	Water fountain	Initial	1.5	1/5/2021	
Adirondack	TH-2-CF-381	11/17/2020	S208	Classroom sink	Initial	19.8	1/5/2021	Removed from service
Adirondack	TH-2-DW-382	11/17/2020	S208 bubbler	Water fountain	Initial	6.8	1/5/2021	
Adirondack	TH-2-CF-383	11/17/2020	S206	Classroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-2-DW-384	11/17/2020	S206 Bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-385	11/17/2020	S206 A boys room (left)	Bathroom sink	Initial	1.4	1/5/2021	
Adirondack	TH-2-BF-386	11/17/2020	S206 A boys room (right)	Bathroom sink	Initial	2.2	1/5/2021	
Adirondack	TH-2-WC-387	11/17/2020	Water cooler near S206 A	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-388	11/17/2020	S204 A girls room (far left)	Bathroom sink	Initial	3.6	1/5/2021	
Adirondack	TH-2-BF-389	11/17/2020	S204 A girls room (middle left)	Bathroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-2-BF-390	11/17/2020	S204 A girls room (middle right)	Bathroom sink	Initial	2.7	1/5/2021	
Adirondack	TH-2-BF-391	11/17/2020	S204 A girls room (far right)	Bathroom sink	Initial	3.0	1/5/2021	
Adirondack	Th-2-CF-392	11/17/2020	S204	Classroom sink	Initial	1.6	1/5/2021	
Adirondack	TH-2-DW-393	11/17/2020	S204 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-394	11/17/2020	S271 B mens room	Bathroom sink	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-395	11/17/2020	S271 C womens room	Bathroom sink	Initial	1.9	1/5/2021	
Adirondack	TH-2-BF-396	11/17/2020	S274	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-2-BF-397	11/17/2020	S273 A boys room (left)	Bathroom sink	Initial	2.3	1/5/2021	
Adirondack	TH-2-BF-398	11/17/2020	S273 A boys room (right)	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-2-BF-399	11/17/2020	S273 B girls room (far left)	Bathroom sink	Initial	3.0	1/5/2021	
Adirondack	TH-2-BF-400	11/17/2020	S273 B girls room (middle left)	Bathroom sink	Initial	3.1	1/5/2021	
Adirondack	TH-2-BF-401	11/17/2020	S273 B girls room (middle right)	Bathroom sink	Initial	2.4	1/5/2021	
Adirondack	TH-2-BF-402	11/17/2020	S273 B girls room (far right)	Bathroom sink	Initial	4.3	1/5/2021	
Adirondack	TH-2-WC-403	11/17/2020	Water cooler near S283 A	Water cooler	Initial	ND	1/5/2021	
Adirondack	TH-2-BF-404	11/17/2020	S283 A boys room (left)	Bathroom sink	Initial	5.0	1/5/2021	
Adirondack	TH-2-BF-405	11/17/2020	S283 A boys room (right)	Bathroom sink	Initial	3.5	1/5/2021	
Adirondack	TH-1-BF-406	11/17/2020	Facility Director bathroom	Bathroom sink	Initial	5.7	1/5/2021	
Adirondack	TH-1-WC-407	12/10/2020	Bottle Fill near S144B	Bottle fill	Initial	ND	1/5/2021	
Adirondack	TH-1-WC-408	12/10/2020	HS Cafeteria front water cooler	Water cooler	Initial	2.2	1/5/2021	
Adirondack	TH-2-CF-409	12/10/2020	S264 sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-DW-410	12/10/2020	S264 bubbler	Water fountain	Initial	1.3	1/5/2021	
Adirondack	TH-2-CF-411	12/10/2020	S266 Sink	Classroom sink	Initial	1.1	1/5/2021	
Adirondack	TH-2-DW-412	12/10/2020	S266 bubbler	Water fountain	Initial	ND	1/5/2021	
Adirondack	TH-2-CF-413	12/10/2020	S260 sink	Classroom sink	Initial	1.0	1/5/2021	
Adirondack	TH-2-DW-414	12/10/2020	S260 bubbler	Water fountain	Initial	1.2	1/5/2021	
Adirondack	TH-2-KF-415	12/10/2020	Faculty lounge	Kitchen sink	Initial	1.5	1/5/2021	
Adirondack	TH-2-CF-416	12/10/2020	S207 C	Classroom sink	Initial	3.2	1/5/2021	
Adirondack	TH-2-CF-417-P	12/10/2020	E269 sink	Classroom sink	Post	2.2	1/5/2021	
Adirondack	TH-2-CF-418-P	12/10/2020	E270 sink	Classroom sink	Post	7.1	1/5/2021	

School Name: Taconic Hills Central School District

Lab ELAP ID#

Analysis Method:

EPA 200.8 REV 5.4

Lab ID	Sample ID#	Collection Date	Sample Location	Outlet Description	Initial/Post	Results $\mu\text{g/L}$ (ppb) (Non-Detect = ND)	Lab Report Receipt Date	Action Taken
Adirondack	TH-2-CF-419-P	12/10/2020	E220 sink	Classroom sink	Post	1.9	1/5/2021	
Adirondack	TH-2-DW-420-P	12/10/2020	E220 bubbler	Water fountain	Post	ND	1/5/2021	
Adirondack	TH-1-CF-421-P	12/10/2020	S180 C (third sink from left to right)	Classroom sink	Post	5.9	1/5/2021	
Adirondack	TH-1-BF-422	12/10/2020	S142 C (left girls room sink)	Bathroom sink	Initial	8.7	1/5/2021	